

vänEE 50H Part no. 44600 (тор роктs) Part no. 44602 (side ports) 47 to 90 CFM (0.4 in. w.g.)



VB0366

#### THE 50H : A COMPACT MACHINE THAT THINKS BIG!

The 50H is offering more airflow than the 40H+ , it's smaller brother, thanks to a higher performance motor. This makes it suitable for larger applications, while remaining easy to install because of it's compact size and port configuration options. With its compact size and 4-inch vertical or horizontal ports, it can be installed in small spaces such as a closet or mechanical room above a hot water tank. The 50H has just one blower (patent pending) and is therefore quieter than any other similar HRV on the market.

- At just 30 lb. (13.6 kg), it can be installed without opening the unit
- Features pressure taps, balancing dampers, integrated hooks and port straps to simplify installation
- Removable terminal block for quicker wall control connections

#### **REPAIRS AND MAINTENANCE**

All parts of the 50H that could need maintenance can be removed in less than five minutes, allowing direct access for easy repairs. The PSC motor is permanently lubricated.

#### WARRANTY

The 50H is protected by a 5-year warranty on parts only. The heat recovery core is covered by a limited lifetime warranty, with the original proof of purchase.

#### Available at:

# HEAT RECOVERY VENTILATOR

#### Controls

- This unit is very simple to operate. Once it is installed, press on its push button, located on the unit top left side, to select high speed, low speed or to stop it (the blower is off but will turn on in response to a wall control signal). The LED (located under the push button) will then show which mode the unit is in.
- For more convenience, this unit can also be controlled by an optional main control. For a complete list of optional main and auxiliary controls available, refer to the *Wall Control Compatibility Chart* on last pages of wall controls specification sheet, available at www.vanee.ca.

For more details about controls, refer to their specification sheet and to the *Main and auxiliary wall control user guide* at www.vanee.ca.

#### Options

- Complete line of registers and diffusers
- · Electric duct heater
- Exclusive wall mounting bracket no. 19255

#### **Defrosting System**

The 50H uses a recirculation defrost method, which maintains balanced air pressure in the home. If there is a call for ventilation from an auxiliary wall control during the defrost cycle, the defrost is put "on hold" while air is exchanged, ensuring that no humid air is recirculated.

OUTSIDE TE	DEFROST CYCLE MIN./			
°C	°F	<b>O</b> PERATING MIN.		
WARMER THAN -5	WARMER THAN 23	No defrost		
-5 то -15	23 то 5	5/30		
-15 то -27	5 то -17	5/20		
-27 AND LESS	-17 AND LESS	7/15		

#### Heat Recovery Core

Dimensions: 10" x 10" x 5.5" (25.4 cm x 25.4 cm x 14 cm)

Exchange surface: 42.3 ft.<sup>2</sup> (3.9 m<sup>2</sup>)

Weight: 4 lb. (1.8 kg)

Material: Polypropylene

Type: Cross flow

Warranty: Limited lifetime

#### **Requirements and standards**

- Complies with the UL 1812 requirements regulating the installation of Heat Recovery Ventilators
- · Complies with the CSA C22.2 no. 113 Standard applicable to ventilators
- Complies with CSA F326 requirements regulating the installation of Heat Recovery Ventilators
- Technical data was obtained from published results of tests relating to CSA C439 Standards

# DIMENSIONS: 50H (SIDE PORTS)

- 1: FRESH AIR TO BUILDING PORT
- 2: EXHAUST AIR FROM BUILDING PORT



NOTE: ALL UNITS PORTS WERE CREATED TO BE CONNECTED TO DUCTS HAVING A MINIMUM OF 4" DIAMETER, BUT IF NEED BE, THEY CAN BE CONNECTED TO BIGGER SIZED DUCTS BY USING AN APPROPRIATE TRANSITION (E.G.: 4" DIAMETER TO 5" DIAMETER TRANSITION).

### Ventilation Performance

External		NET SUPPLY		GROSS AIR FLOW						
STATIC PRESSURE		AIR FLOW		SUPPLY			Exhaust			
Pa	IN. W.G.	L/S	CFM	м <sup>3</sup> /н	L/S	CFM	м <sup>3</sup> /н	L/S	CFM	м <sup>3</sup> /н
25	0.1	47	100	168	47	100	170	46	97	164
50	0.2	45	95	161	45	95	163	44	93	158
75	0.3	44	93	158	44	93	160	43	91	156
100	0.4	42	89	153	43	91	155	41	87	148
125	0.5	40	85	143	40	85	144	39	83	141
150	0.6	37	78	133	37	78	134	37	78	133
175	0.7	35	74	126	35	74	126	35	74	126
200	0.8	33	70	117	33	70	119	33	70	119
225	0.9	30	64	107	30	64	108	31	66	119

# **E**NERGY **P**ERFORMANCE

SUPPLY Temperature		NET AIR FLOW			Power consumed	SENSIBLE	Adjusted sensible	Apparent sensible	LATENT RECOVERY/
°C	°F	L/S	CFM	м <sup>3</sup> /н	WATTS	RECOVERY	RECOVERY EFFICIENCY	SENSIBLE EFFECTIVENESS*	MOISTURE TRANSFER
HEATING									
0	32	22	47	80	39	66	71	75	0
0	32	30	64	109	55	63	68	72	0
-25	-13	23	49	82	49	60	63	78	0.04
-25	-13	30	64	109	63	55	59	70	0.05

\*Data not certified by HVI.

NOTE: All specifications are subject to change without notice.

### **S**PECIFICATIONS



Venmar Ventilation ULC, 550 Lemire Blvd., Drummondville, Québec, Canada J2C 7W9 vanee.ca 800-567-3855



OF